



## REQUEST FOR INFORMATION

- **Contract Number:** CNR048
- **Project:** Interstate 24, Bridge Replacement over Spring Street and Oldham Street
- **Date:**
- **Question:**

Sheet BR-122-47 "Concrete Repairs" calls for a ¼" hook bolt with 4" square plate washer. The detail shows a ¼" stud with 4" square plate washed and nut. Please clarify.

- **TDOT Response:**

The bolt should be bent into a hook shape after the plate washer and bolt are installed. The "hook" part of the bolt is omitted for clarity of the detail.

\* Please email questions to Jamie Fitzpatrick at [Jamie.Fitzpatrick@tn.gov](mailto:Jamie.Fitzpatrick@tn.gov).